

Northbrook, Illinois • (847) 272-8800  
Melville, New York • (516) 271-6200  
Santa Clara, California • (408) 985-2-  
Research Triangle Park,  
North Carolina • (919) 549-1400  
Camas, Washington • (360) 817-5500



DAY-IMPEX LTD  
MR G BERGER  
STATION WORKS  
EARLS COLNE  
ESSEX, COLCHESTER  
C06 2ER ENGLAND UNITED KINGDOM



Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your UL project.

VNIV2 September 25, 2002  
Sprinklers, Automatic and Open - Component

DAY-IMPEX LTD  
STATION WORKS EARLS COLNE ESSEX, COLCHESTER, C06  
2ER ENGLAND UNITED KINGDOM

EX3948

Class Bulb Heat Responsive Element

Model  
Style 937  
Style 941

Temperature Rating, F  
135, 155, 175, 200, 286, 360  
135, 155, 175, 200, 286

Marking: Company name, model or style designation and UL Recognition Mark.

See General Information Preceding These Recognitions  
For use only in equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

Replaces EX3948 dated August 3, 1998  
701556001 Underwriters Laboratories Inc.®

D11/0147700  
10

For information on placing an order for UL Listing Cards in a 3 x 5 inch card format, please refer to the enclosed ordering information.

UNDERWRITERS LABORATORIES INC.

A not-for-profit organization  
dedicated to public safety and  
committed to quality service